

CITY OF CHARLOTTESVILLE  
PUBLIC WORKS  
FACILITIES MAINTENANCE



DATE: August 05, 2020  
ADDENDUM NO. 7  
NUMBER OF PAGES: 1  
SOLICITATION REFERENCE: IFB#: SMITH AQUATIC CENTER INDOOR AIR QUALITY RENOVATIONS PROJECT/20-52  
TITLE: Smith Aquatic Center Indoor Air Quality Renovations  
BIDS/PROPOSALS DUE: August 07, 2020 at 2:00 PM local prevailing time

This addendum has been issued to address the following:

1. Refer to sheet M-9, number 23; add the following to Paragraph X:

*THE WATER TREATMENT FIRM SHALL PROVIDE A COMPLETE, PRE-MANUFACTURED CHEMICAL INJECTION PUMPING SYSTEM FOR THE CONDENSER WATER LOOP AND FOR THE TOWER DISTRIBUTION LOOP – INSTALLATION BY THE CONTRACTOR. INJECTION SYSTEM FOR THE CONDENSER WATER LOOP SHALL BE LOCATED IN MECHANICAL 210. INJECTION SYSTEM FOR THE TOWER DISTRIBUTION SYSTEM SHALL BE LOCATED AT THE TOWER IN THE FENCED EQUIPMENT YARD. THE CONTRACTOR SHALL COORDINATE INJECTION SYSTEM INSTALLATION AND CONNECTIONS WITH THE TOWER MANUFACTURER. THE CONTRACTOR SHALL PROVIDE AND INSTALL A CONCRETE PAD-MOUNTED STORAGE ENCLOSURE, MINIMUM 4'W X 2'D X 5'H FOR HOUSING THE TOWER DISTRIBUTION INJECTION SYSTEM. STORAGE ENCLOSURE SHALL BE HEAVY DUTY RESIN CONSTRUCTION, WEATHER RESISTANT, WATER RESISTANT, UV RESISTANT, AND RUST RESISTANT WITH A MAXIMUM WIND RATING OF 65 MPH. ENCLOSURE SHALL HAVE PADLOCK READY DOUBLE-DOORS FOR EASY ACCESS TO INJECTION SYSTEM COMPONENTS AND SHALL BE SECURELY ANCHORED TO THE CONCRETE PAD. ENCLOSURE LOCATION SHALL NOT IMPEDE SERVICE ACCESS CLEARANCES FOR THE TOWER AND ITS COMPONENTS. PIPING PENETRATIONS SHALL BE GROMMETED AND SEALED WEATHER-TIGHT. ENCLOSURE COLOR TO BE CONFIRMED BY OWNER.*

Note: A signed acknowledgment of this addendum must be received at the location indicated on the solicitation either prior to the solicitation due date and hour or attached to your bid/proposal. Signature on this addendum does not substitute for your signature on the original bid/proposal document. The original bid/proposal document must be signed.

Respectfully,

Ryan Dewyea  
Project Manager

\_\_\_\_\_  
Name of Bidder/Offeror

\_\_\_\_\_  
Signature & Title

\_\_\_\_\_  
Date